

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7167-1126:116

Page 1 of 1

**CATEGORY:** Control Units (Household)

**LISTEE:** Interactive Technology Inc, 2266 North Second St., North Saint Paul, MN 55109  
Contact: \*Randy Libersky (651) 773-2235

**DESIGN:** Model "Simon II" 60-776-95R, \*60-776-02-95R, \*60-845-95R combination household fire and burglary alarm control unit. Refer to listee's data sheet for detailed product description and operational considerations. System components:

60-776-95R, \*60-776-02-95R, \*60-845-95R  
60-671  
\*22-091

Control Unit  
Manual Held Keypad  
Class 2 Transformer

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system under normal condition for at least 24 hours (battery standby) and followed by not less than 4 minutes of alarm as required by code.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a household fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:**

1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.
2. Fire Alarm Verification feature (delay of fire alarm signal) in household system shall NOT be used in California.

\*Rev. 11-30-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager